



SHRI MATA VAISHNO DEVI UNIVERSITY

P.O. KAKRYAL- 182 320,, KATRA (J&K)

*TENDER
FOR*

*Supply , Installation , Testing and Commissioning of
High Mast lighting System near Basohli Boys Hostel
& Paragola area near Central Library (02 Nos)*

AT SMVD UNIVERSITY CAMPUS, KATRA

*TENDER DOCUMENT
Dec2017*

NOTICE INVITING TENDER

Shri Mata Vaishno Devi University, established under the Act No. XII of 1999 of J&K Legislature, invites sealed Tenders from reputed and experienced Agencies/Firms/authorized dealers for the jobs as mentioned in the tender document.

S. No.	Description of work	Estimated cost (in Rs)	EMD (in Rs.)
1.	Supply , Installation , Testing and Commissioning of High Mast lighting System near Basohli Boys Hostel & Paragola area near Central Library (02 No) at SMVDU Campus , Kakryal, Katra.	13,00,000.00	26,000.00

TERMS AND CONDITIONS

1. The tender documents shall be download from university website www.smvdu.net.in. Applications for tender documents shall be accompanied by Rs. 1000/- (Rupees One Thousand only) towards the cost of tender documents in the shape of demand draft payable in the name of 'The Registrar, SMVD University Campus, P.O. Kakryal – 182 320, Katra (J&K), which will not be refunded under any circumstances. The detailed tender document can be downloaded from our website www.smvdu.net.in
2. The Earnest Money Deposit in the shape of DD drawn on a scheduled or nationalized bank and pledged in favour of Registrar, SMVD University must accompany each tender, failing which the tender will be summarily rejected.
The Earnest Money will be returned to unsuccessful Tenderers after the issue of the Letter of Allotment of supply order to the successful Tenderer. The Earnest Money will not bear any interest.
3. Income Tax Return for last 3 years should be submitted along with tender documents.
4. Latest Sale Tax Clearance Certificate should also be submitted.
5. The tenderer must have executed a similar or equivalent high mast lighting system anywhere and a copy of the same shall be furnished along with the tender documents.
6. Sealed Tenders in the prescribed Tender Form addressed to 'The Registrar, SMVD University Campus, P.O. Kakryal – 182 320, Katra (J&K), in a sealed envelope and super scribed with "Tender for Supply , Installation , Testing and Commissioning of High Mast lighting System near Basohli Boys Hostel & Paragola area near Central Library (02 No)" at SMVD University campus, Katra shall be submitted in The office of Registrar SMVDU or before 12-01-2018 Time **1500 hrs.**
7. The tender shall be opened on same date or any other convenient date in presence of such tenderer who may choose to be present at the time of opening.

For and on behalf of
Shri Mata Vaishno Devi University

Registrar
SMVD University

Detailed Terms and condition to notice inviting Tender for supply of electrical items

- The tender offer shall have to be accompanied with an Earnest Money in the shape of DD of Rs **26000/-** only on any scheduled bank pledge to Registrar Shri Mata Vaishno Devi University Katra , without which tender / offer shall be rejected outrightly. The earnest money in the case of successful tenderer shall be kept as security deposit whereas in case of unsuccessful tenderer the same shall be released after finalization of contract/supply order.
- The rates quoted shall be mentioned as per the format enclosed and F.O.R site, KATRA and inclusive of all taxes /charges.The firm shall also produce authorized dealer certificate of the items from the company.
- The tenderer shall quote the rates strictly as per brand and specification mentioned.
- The quantity mentioned in the tender are indicative in nature and can be increased / decreased within accepted variation.
- The tenderer should be filled in neatly quoting the rates both in words and figures, without any cutting/overwriting. In case of any cutting /overwriting the same shall be authenticated under the signature of the tenderer.
- The rates quoted should be net inclusive of all taxes,
- The university reserves the right to reject , accept or prefer any tender in part or full without assigning any reason whatsoever at any stage.
- The University reserve the right to negotiate the quoted rates, term and condition with the lowest tenderer or any of the other tenderer to ascertain the suitability of the acceptable offer.
- The tender has to be submitted on the prescribed format of the tender /Letter head of the firm.The tender should be duly sealed in an envelope super scribing the word “ Tender for“Tender for Supply , Installation , Testing and Commissioning of High Mast lighting System near Basohli Boys Hostel & Paragola area near Central Library (02 No)” and addressed to Registrar Shri Mata Vaishno Devi University Katra .
- Conditional, illegible, ambiguous tender(s) and tender(s) without DD and received after the stipulated date and time shall be out rightly rejected.
- The tenderer shall not be entitle to revoke or withdraw their tenders or vary or modify.
- The tender shall be opened on same date or any other convenient date in presence of such tenderer who may choose to be present at the time of opening.
- The offer shall remain valid and open for acceptance for a period of 60 days from the date of opening of tenders. Should the tenderer fail to keep the tender open for acceptance as stated above,or if the tenderer withdraw his tender before the expiry of the said period or makes any modifications in the terms and condition of the tenders , the earnest money/security deposited by the tenderer shall be forfeited without any notice.
- The cost of the tender for in the shape of DD for Rs 1000/- must accompany the downloaded tender form in absence of which the offer shall not be accepted. Tender duly complete in all respects must be received in the office through speed post/registered post in SMVDU university upto 12-01-2018 , 1500 hrs.

- The Registrar SMVDU reserve the right to accept or reject any tender / all tenders without assigning any reason thereof.
- The tenderer must quote the warranty of the equipment as applicable.
- The rates to be quoted shall be applicable for a period of 1 year from the date of issue of supply order in favour of the success bidder. The supplier shall have to supply the material against the supply order issued by this office from time to time during the rate approval period.
- Payment shall be made after the successful commissioning of High Mast lighting system (02 No) SMVDU katra..
- The approved supplier (s) shall be bound to supply the material of the make /brand/quality mentioned in the tender.
- On receipt, the material shall be inspected/checked by inspection committee and if the same found of inferior quality /defected, it will be rejected and SMVDU shall be at liberty to have the same procured from the open market at the risk and cost of the supplier whereby the original supplier shall be liable to pay the extra cost , if any , involved in the process.
- In case of approved supplier fails to supply the material within the stipulated period the following penalty shall be imposed for the delay : (i) up to 15 days @1% (ii) from 16 days to 30 days @2% (iii) Beyond 30 days , the supply order will be deemed to have been cancelled , the EMD of the supplier shall be forfeited in favour of SMVDU, katra and the rates approval order shall be treated as cancelled .The material shall then be procured from the open market at the risk and cost of the defaulter supplier , where after the defaulter supplier may be debarred from any further dealing with SMVDU.
- In case of incomplete supply received an amount equal to 2% of the total value of non supplied material shall be deducted from the due payment of the supplier.
- In case of any dispute arising out of contract, the Registrar SMVDU shall be the Arbitrator and his decision shall be final.
- All the dispute are subject to jurisdiction in the court of law at Jammu only.
- These terms and condition will form a part of the contract/agreement/rate approval order with the successful tenderer (s).
- **The tenderer must have executed a similar or equivalent high mast lighting system anywhere and a copy of the same shall be furnished along with the tender documents.**

Sd/-

Registrar

SMVD university katra

Seal and signature of the Tenderer

TENDER FORMAT

Name of the Tenderer

Amount of DD with number and date -----
To,
The Registrar
Shri Mata Vaishno Devi University
Katra

Sir,
I----- from M/s -----
Hereby submits my tender for supply of following material as per details given below:-

Specifications for Supply , Installation and commissioning of High Mast light at parabola area central library SMVDU, Kakryal, Katra.

S.No	Item Description	Unit	Quantity	Unit Rate	Amount
1	Supply , Installation of Hot Dip Galvanised 16m High Mast for LED flood lights with motorised carriage of aproved makes with its accessories. Mast shall be into two sections hot dip galvanised and suitable for wind velocity as per IS:875. It should also include accessories of the high mast including head frame, steel wire rope 6mm (Dia 7/19 construction). Trailing cable, double drum winch, , galvanised lantern carriage suitable for required luminaries symmetrically or asymetrically as shown in the lighting design and its control gear boxes, lighting final. The mast shall have integral power tool installed in the base compartment for its operation. Set foundation bolts manufactured from special steel along with nuts , washers, anchor plates and templates. Make: Philips/ Wipro/ Bajaj/Havells	Each	2		
2	Providing reinforced cement concrete foundation of size and design as per Mast Manufacturer.	Each	2		
3	Supply, Installation , Testing and commissioning of 170W LED flood lights similar to BVP410 LED 172 CW HE NB FG S3 XT of Philips on High Mast.	Each	12		

4	Supply, Installation, Testing and Commissioning of Floor Mounted Low voltage Outdoor panel IP54 Suitable for operation on 433V 3 Phase, 50Hz Supply, Made of 2.0mm CRCA Sheet enclosure with Aluminium bus bar Four wire with following switchgears and metering . Necessary arrangement be made for termination of incoming cable and outgoing cables. LT Panel shall be manufactured as per IS8623.	Set	02		
	Incomer				
	63A 4Pole MCCB 25kA-1 No.				
	60A 4 Pole contactor- 1No.				
	Digital Astronomical based time switch equivalent to 1 Channel Alpharex D22 Astro - 1No.				
	Surge protection Device Class B +C 3P+N Legrand/OBO				
	Bushar shall be Aluminium TPN 200A duly supported on DMC insulators and covered with heat shrinkable color coded PVC sleeves.				
	Outgoings				
	32A 2 Pole MCB 10 kA-8 Nos				
	Make of MCCB/Contactor/TimeSwitch/SPD: Schneider (Acti-9), Legrand (DPX3), Siemens (Betagard)/L&T				
5.	Supply and laying of 3 core 2.5 sqmm cable form panel to LED lights including connection at both ends.	Mtrs	400		
6.	Supply and laying of main cable from existing transformer station pannel up to proposed panel for high mast lighting (4 X 35 sq mm Armoures)Through as MCCB 4P,63A	Mtrs	600		
7.	Chemical earthing complete in all respect	Set	4		
	Total Amount				