

Annexure-A

| S.NO | PARTICULARS | Unit | Qty | Rate | Amount |
|------|--|------|-----|------|--------|
| 1 | Erectioning of Steel tubular or Rail pole in ground including excavation and refilling and secured with holding clamp , bolts, nuts etc as required.(ST pole , clamp , nut bolts will be supplied by SMVDU) | | | | |
| | (i) 8 meter steel tubular pole | No | 150 | | |
| | (ii) 9 meter steel tubular pole | No | 30 | | |
| 2 | Fixing of Shackle Insulator (Porcelain Make) with Shackle Insulator Assembly Hardware made of MS flat 40mm x6mm of 16" length with 2 no 16mm dia hole to be mounted on 4"Clamp on steep tubular pole. (Shackle insulator, Complete Assembly, will be supplied by SMVDU) | No | 750 | | |
| 3 | Erectioning on ACSR conductor Weasel (30 mm ²) on steel tubular poles (3 phase 4 wire) complete as required.(ACSR conductor will be supplied by SMVDU) | km | 26 | | |
| 4 | Laying overhead on steel tubular poles LT aluminium Cable 3.5 Core Armoured 35 Sqmm.(LT cable will be supplied by SMVDU) | mtr | 500 | | |
| 5 | Fixing (Wherever required) of Nuts and Bolts of various sizes (3",4",5"and 6") .(Nuts & Bolts will be supplied by SMVDU) | kg | 400 | | |
| 6 | Fixing of GI strip 25x3mm as required . (GI strip will be supplied by SMVDU) | Kg | 150 | | |
| 7 | Fixing Clamps of sizes 4",5" and 6" of MS flat of 40mmx6mm with 2no 16mm Holes suitable for ST pole. (Clamps will be supplied by SMVDU) | No | 150 | | |
| 8 | Painting of poles , Channel, Clamp , Nuts bolts with AluminiumPaint as required. (Paint will be supplied by SMVDU) | Ltr. | 440 | | |
| 9 | Erectioning of Galvanised Stay Set with 50x8mm stay clamp, guy insulator(1 Nos.),anchor plate (200x 200 x 6 mm), nut-bolts, 1.8m long, 16 mm diameter solid GS stay rod including using of GI stranded guy wire of size 7/3.15 mm and 7/2.0 mm . (Stay set complete and guy wire will be provided by SMVDU) | Nos | 70 | | |

