

श्री माता वैष्णो देवी विश्वविद्यालय



Shri Mata Vaishno Devi University
University Campus: Kakryal, Katra -182 320
01991-285535, 285634, Fax: 01991-285573

No: SMVDU/Engg/20/101

Dated : 24.01.2020

Shri Mata Vaishno Devi University is interested to invite the quotations for below mentioned items of work for laying of 11KV line with allied work for stable electrical power supply to sewerage treatment plant 500KLD near Basohli Hostel Block C&D at SMVDU campus Kakryal Katra :-

S.No	Material Description	Unit	Qty	Rate	Amount
1.	Dismantling of required existing LT-3 Phase 4 wire Over-head conductor Network from existing ST Poles along with their accessories of insulators, clamps, Nut bolt etc. Complete job as required to satisfaction of Engineer In charge	Set	1Job		
2.	Supply And Fixing of GOAB 3 Pole Nine Insulator 400 Amp Switch with Coupling Rod , Handle and Operating GI Pipe 1 inchdia and 6 mtr long "B" Class;Polymer Type Make : Jaipuria Brothers / Naresh Potteries/Azad welding works.	SET	1Job		
3.	Supply and fixing of LA set Line Type Gapless for 11 KV 9 KA Polymer/Porcelain Type. Make :Oblum / Lamco / Adinath Industries.	SET	3		
4.	Supply and Erection of ST Pole 11 mtr 410 SP 56 with Base Plate of 350mmx350mx5mm thick painted with two coats of red oxide and with 2 coats of Aluminium Oxide	NOS	3		
5.	Supply and Erection of ST Pole 9 mtr 410 SP 32 with Base Plate of 350mmx350mx5mm thick painted with two coats of red oxide and with 2 coats of Aluminium Oxide	NOS	3		
6.	Supply and Fixing of Pin Insulator Polymer Type 5 KN for 11 KV with 24 mm FRP ROD. Make : Naresh Potteries / yamunaDensons / RR India	NOS	120		
7.	Supply and Fixing of Disc Insulator Polymer Type complete with fitting (45 KN) with 16 MM FRProd.Make : Naresh Potteries / yamunaDensons / RR India	NOS	24		
8.	Supply & Fixing 11 KV Bridling "V" type cross Arm as per REC standard with 2 coats of red oxide and 2 coats of Aluminium Oxide.	NOS	30		

Handwritten signatures and initials in the bottom left corner, including a date '24/1/20'.

9.	Supply & Fixing 11 KV Pole top Bracket as per REC Standard with 2 coats of red oxide and 2 coats of Aluminium Oxide.	NOS	30		
10.	Supply & fixing of G I wire 8 SWG (4 mm Dia)for garn betting for road Crossing	Mtr	250		
11.	Supply & fixing of G I Barbed Wire 12 SWG (Strand) x 14SWG (barb) with 3" Barb Spacing with min vertical height of 2 feet on ST poles	KGS	120		
12.	Supply &fixing of Galvanized stay set with 50 x8 mm stay clamp, guy insulator (2 Nos), Anchor plate (200x 200 x 6 mm) Nut Bolts 2 No. turn Buckles 1.8m long 16 mm Dia meter solid GS stay rod 2 Nos 7/3.15 mm Dia GI stranded wire complete -2 Sets excluding cost of GI Guy wires 7/3.15mm.	SET	15		
13.	Supply of GI Guy Wire 7/3.15 mm	KGS	75		
14.	Supply fabrication and Fixing of Channel 75x40 mm duly painted with 2 coats of Red oxide and 2 coats of Aluminium Paint	KGS	350		
15.	Supply fabrication and Fixing of Angle 50mm x 6 mm duly painted with 2 coats of Red oxide and 2 coats of Aluminium Paint	KGS	150		
16.	Supply fabrication and Fixing of Angle 35mmx5mm duly painted with 2 coats of Red oxide and 2 coats of Aluminium Paint	KGS	50		
17.	Supply fabrication and Fixing of Flat Clamps 40 mm x 6mmx30mm average long duly painted with 2 coats of Red oxide and 2 coats of Aluminium Paint	NO	120		
18.	Laying and stringing of ACSR Conductor (Weasel) in 3 Phase formation on ST Poles as required (Weasel Conductor ACSR will be provided by SMVDU Store)	Mtr	2000		
TOTAL AMOUNT INCL OF TAXES					

You are requested to kindly send your quotations for supply and execution of works as above by giving rates, including special discount for this organization. The sealed quotations addressed to the Registrar should reach the office of the Registrar through speed post, registered post, reputed courier service or can be personally submitted to the office of the Registrar by or before **14-02-2020 upto 3.00p.m.** positively.

Terms & Conditions:-

1. Only Govt. Registered agencies are eligible to submit their Quotes and must have an experience of laying of HT/LT Networks.
2. The D.D. of Rs.10,000/- of any nationalized bank in the favor of Registrar be enclosed without which quotation shall not be entertained.
3. The D.D. shall be returned to unsuccessful agencies after the allotment of the work to LI.
4. This is only an enquiry and not a Work Order
5. The agency may visit the site before quotating the rates and may contact the Engineering Section for any further clarification.

9/2/20
2/2/20
9/2/20
9/2/20
9/2/20

6. All the disputes are subject to jurisdiction in the court of law, Jammu in Jammu District only.
7. In case of any dispute arising out of the work order, the decision of the Arbitrator, who shall be nominated by the Vice-Chancellor SMVDU, shall be final and binding upon both the parties.
8. SMVDU reserves the right to terminate the order during its validity without assigning any reason thereof.


University Engineer
SMVDU


